



NOTICE OF APPROVAL

AVIS D'APPROBATION

Issued by statutory authority of the Minister of Industry
for:

Émis en vertu du pouvoir statutaire du ministre de
l'Industrie pour:

TYPE OF DEVICE

Instrument Transformer: Voltage

TYPE D'APPAREIL

Transformateur de mesure: tension

APPLICANT

R. L. Brews Limited
4910 Builders Rd, SE,
P.O. Box 5340, Stn A
Calgary, Alberta,
Canada , T2H 1X6

REQUÉRANT

MANUFACTURER

Electrotecnica Artech Hermanos
P. O. Box 1, 48100
Munguia, Vizcaya, Spain

FABRICANT

MODEL(S)/MODÈLE(S)

VTD-52

RATING/ CLASSEMENT

46000-115/115V
Accuracy class/ Classe de précision: 0.3WXYZ, 0.6ZZ
Frequency/ fréquence : 60 Hz
Voltage Class/ Catégorie de tension: 52 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

SUMMARY DESCRIPTION:

The VTD-52 is a Line-Line version of the UTD-52 approved pursuant to Notice of Approval T-0164.

RATIOS/TAPS

The following ratios and taps are approved for revenue metering:

46000-115V	(X ₁ -X ₂)	0.3WXYZ, 0.6ZZ
46000-115V	(Y ₁ -Y ₂)	0.3WX

REVISION

Rev. 1

The purpose of revision 1 is to include additional accuracy class (0.3WXYZ).

EVALUATED BY

David Lau, Original and Rev. 1
Complex Approvals Examiner
Tel : (613) 952-0647
Fax : (613) 952-1754

REMARQUE: Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

DESCRIPTION SOMMAIRE:

Le VTD-52 est une version ligne à ligne du transformateur UTD-52 approuvé en vertu de l'avis d'approbation T-0164.

RAPPORTS/ENROULEMENTS

Les rapports et enroulements suivant sont approuvés à fins de facturations:


RÉVISION

Rév. 1

La révision 1 vise à inclure la classe de précision (0.3WXYZ)

EVALUÉ PAR

David Lau, originale et Rév. 1
Examineur d'approbations complexes
Tél : (613) 952-0647
Fax : (613) 952-1754



APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local inspection office of Industry Canada.

Original copy signed by:

René Magnan, P. Eng
Director
Approval Services Laboratory

APPROBATION:

La conception, la composition, la construction et le rendement du(des) type(s) de compteurs identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de la dite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz. Les exigences de scellage et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 du dit règlement. Sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local d'Industrie Canada.

Copie authentique signée par:

René Magnan, ing.
Directeur
Laboratoire des services d'approbation

Date: **OCT 21 2002**

Web Site Address / Adresse du site internet:
<http://mc.ic.gc.ca>