



Consumer and
Corporate Affairs Canada
Legal Metrology

Consommation
et Corporations Canada
Métrologie légale

APPROVAL No. - N° D'APPROBATION

AE-0446

MAY - 8 1982

NOTICE OF APPROVAL

Issued by statutory authority of the Director of the Legal Metrology Branch of Consumer and Corporate Affairs Canada for (category of device):

Dual Ratio Current Transformer

APPLICANT / REQUÉRANT:

Corimpex International Inc.
One Canyon Avenue, Suite 902
Toronto, Ontario
M3H 4X8

MODEL(S) / MODÈLE(S):

IK5-200-801S

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du directeur de la Métrologie légale, Consommation et Corporations Canada, pour (catégorie d'appareil):

Transformateur de courant à deux rapports de transformation

MANUFACTURER / FABRICANT:

Square D Company
Clearwater, Florida
USA

RATING / CLASSEMENT:

800/400 - 5 A

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of principal features only.

REMARQUE: Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

SUMMARY DESCRIPTION:

Accuracy Rating: 0.3B1.8
 RF (Rating Factor):
 Low Ratio: 2.0
 High Ratio: 1.5
 Frequency: 60 Hz
 Nominal Voltage Class: 34.5 kV
 LIL (Lightning Impulse Level): 200 kV
 Style: Post type.

The type IK5-200 current transformer is a porcelain, post type, oil insulated with the magnetic cores mounted in a metallic tank at the top.

APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the said Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local inspection office of Consumer and Corporate Affairs Canada.



W.R. Virtue

Chief,
 Legal Metrology Laboratories

DESCRIPTION SOMMAIRE:

Classe de précision: 0.3B1.8
 Facteur de surcharge:
 Rapport faible: 2.0
 Rapport élevé: 1.5
 Fréquence: 60 Hz
 Catégorie de tension nominale: 34.5 kV
 Tension de tenue au choc de foudre: 200 kV
 Style: support rigide

Les transformateurs de courant de type IK5-200 sont des transformateurs isolés à l'huile à support rigide en porcelaine dont les noyaux magnétiques sont installés dans un réservoir métallique placé au haut du support.

APPROBATION:

La conception, la composition, la construction et le rendement du (des) type(s) de compteurs identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis sous la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellement, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis sous la Loi sur l'inspection de l'électricité et du gaz. Les exigences de scellement et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. Sauf dans le cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Consommation et Corporations Canada.

MAY - 8 1992

Date

Chef,
 Laboratoires de la Métrologie légale