



Consumer and
Corporate Affairs Canada
Legal Metrology

Consommation
et Corporations Canada
Métrologie légale

APPROVAL / AVIS D'APPROBATION

AE-0451

MAY 29 1992

NOTICE OF APPROVAL

Issued by statutory authority of the Director
of the Legal Metrology Branch of Consumer
and Corporate Affairs Canada for (category
of device):

Current Transformer

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du
directeur de la Métrologie légale,
Consommation et Corporations Canada,
pour (catégorie d'appareil):

Transformateur de courant

APPLICANT / REQUÉRANT:

Instrument Transformers Inc.
1907 Calumet Street
Clearwater, Florida 34625
USA

MANUFACTURER / FABRICANT:

Instrument Transformers Inc.
Clearwater, Florida
USA

MODEL(S) / MODÈLE(S):

Series/Série 141

RATING / CLASSEMENT:

Primary Current/Courant au primaire:
400, 500, 600, 800, 1000, 1200, 1500,
2000, 2500, 3000, 4000, 5000, 6000 A

Secondary Current/Courant au secondaire:
5 A

NOTE: This approval applies only to
meters, the design, composition,
construction and performance of which are,
in every material respect, identical to that
described in the material submitted, and
that are typified by samples submitted by
the applicant for evaluation for approval in
accordance with sections 13 and 14 of the
Electricity and Gas Inspection Regulations.
The following is a summary of principal
features only.

REMARQUE: Cette approbation ne vise que
les compteurs dont la conception, la
composition, la construction et le
rendement sont identiques, en tout point, à
ceux qui sont décrits dans la documentation
reçue et pour lesquels des échantillons
représentatifs ont été fournis par le
requérant aux fins d'évaluation,
conformément aux articles 13 et 14 du
Règlement sur l'inspection de l'électricité et
du gaz. Ce qui suit est une brève
description de leurs principales
caractéristiques.

Canada

75-12100-0073 (01-90) 57

SUMMARY DESCRIPTION:

Accuracy Rating:

400 A: 0.6B0.9
 500, 600 A: 0.3B0.5, 0.6B0.9
 800, 1000 A: 0.3B0.9, 0.6B1.8
 1200 to 5000 A: 0.3B1.8

RF (Rating Factor):

1.33 @ 30°C
 1.0 @ 55°C


Frequency: 60 Hz
 Nominal Voltage Class: 600 V
 Lightning Protection Level: 10 kV
 Style: Window, indoor.

The core and winding are completely encased in a molded plastic case. The model suffix varies according to the ratio.

APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the said Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local inspection office of Consumer and Corporate Affairs Canada.



W.R. Virtue

Chief,
 Legal Metrology Laboratories

DESCRIPTION SOMMAIRE:

Classe de précision:

400 A: 0.6B0.9
 500, 600 A: 0.3B0.5, 0.6B0.9
 800, 1000 A: 0.3B0.9, 0.6B1.8
 1200 à 5000 A: 0.3B1.8

Facteur de surcharge:

1.33 à 30°C
 1.0 à 55°C

Fréquence: 60 Hz

Catégorie de tension nominale: 600 V
 Tension de tenue au choc de foudre: 10 kV
 Style: À fenêtre intérieure.

Le noyau et les enroulements sont complètement abrités dans un boîtier en plastique moulé. Le suffixe du numéro de modèle varie en fonction des rapports de transformation.

APPROBATION:

La conception, la composition, la construction et le rendement du (des) type(s) de compteurs identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis sous la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellement, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis sous la Loi sur l'inspection de l'électricité et du gaz. Les exigences de scellement et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. Sauf dans le cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Consommation et Corporations Canada.

MAY 29 1992

Date

Chef,
 Laboratoires de la Métrologie légale