



Industry
Canada

Industrie
Canada

Legal Metrology
Branch

Direction de la
métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa (Ontario)
K1A 0C9

Telephone: (613) 952-0635
FAX: (613) 952-1754

Téléphone: (613) 952-0635

File No.: 06565
Project: AP-EL-93-0077
Date: 1994-02-15


Schlumberger Industries
Sangamo Electricity Division
215 Laird Drive
Toronto, Ontario
M4G 3X1
Attention: Mr. Marc Purc

Dear Mr. Purc:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval AE-0465. It is noted that these devices may be manufactured with redesigned current coil assemblies. The redesign consists of modified current coils and a factory power factor adjustment on the current coil separator/insulator. This adjustment consists of a printed circuit board containing six conductive rings which may be pierced, thus providing small incremental steps of inductive adjustment.

I am advised by the Electrical Metrology Laboratory that its evaluation of the proposed modifications indicates that they do not adversely affect the performance of the meter. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the notice of approval are being informed by copy of this letter.

Yours truly,



H.L. Fraser, Chief
Electricity and Gas

cc: Approvals Mailing List

Canada