

AE-0574.





Industry Canada  
Legal Metrology Branch

Industrie Canada  
Direction de la métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa (Ontario)  
K1A 0C9

Telephone: (613) 952-0835

Téléphone: (613) 952-0835

Project: AP-EL-95-0041  
Date: 1995-06-13

Quadlogic Controls Corporation  
520 Broadway, 6th Floor  
New York, New York  
USA 10012  
Attn.: Mr. Doron Shafrir

Dear Mr. Shafrir:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval AE-0574. It is noted that these devices will be equipped with firmware versions, for the indicated voltage ratings, as follows:

120 V (ac): 190111[XX]  
208 V (ac): 190511[XX]  
277 V (ac): 190211[XX]  
480 V (ac): 190611[XX]  
347 V (ac): 190411[XX]  
600 V (ac): 190811[XX]

where "XX" represents internal Quadlogic numbers that pertain to various parameters contained within the meter.

I am advised by the Electrical Metrology Laboratory that their evaluation of the proposed modifications indicates that they do not adversely affect the performance of the meter. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

H.L. Fraser, Director  
Electricity and Gas

cc: Approvals Mailing List



Industry Canada  
Legal Metrology Branch

Industrie Canada  
Direction de la métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa (Ontario)  
K1A 0C9

Telephone: (613) 952-0635

Téléphone: (613) 952-0635

Project: AP-EL-95-0041  
Date: 1995-06-13

Quadlogic Controls Corporation  
520 Broadway, 6th Floor  
New York, New York  
USA 10012  
Attn.: Mr. Doron Shafir

Monsieur,


Nous accusons réception de l'avis de modification que vous nous avez envoyé récemment conformément à l'article 13 du Règlement sur l'inspection de l'électricité et du gaz, au sujet des appareils approuvés en vertu de l'avis d'approbation AE-0574. Il est à noter que ces appareils seront équipés de versions de microprogrammation, pour les tensions nominales indiquées, comme suit:

120 V (c.a.): 190111[XX]  
208 V (c.a.): 190511[XX]  
277 V (c.a.): 190211[XX]  
480 V (c.a.): 190611[XX]  
347 V (c.a.): 190411[XX]  
600 V (c.a.): 190811[XX]

où "XX" représente les nombres Quadlogic internes relatifs aux divers paramètres contenus dans le compteur.

Après avoir étudié les modifications proposées, le Laboratoire de l'électricité (Métrologie légale) me signale que ces modifications ne nuisent pas au rendement du compteur. En conséquence, les modifications sont acceptées et intégrées de facto dans l'avis d'approbation susmentionné. Tous ceux qui ont reçu l'avis d'approbation sont avisés de cette décision par une copie de la présente lettre.

Je vous prie d'agréer mes salutations distinguées.

  
H.L. Fraser, Director  
Electricity and Gas

cc: Approvals Mailing List