



Industry
Canada

Industrie
Canada

Legal Metrology
Branch

Direction de la
métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa (Ontario)
K1A 0C9

Telephone: (613) 952-0635
FAX: (613) 952-1754

Téléphone: (613) 952-0635

File No.: 06565
Project: AP-EL-94-0072
Date: 1994-12-20

Asea Brown Boveri Inc.
249 Dufferin Street
Alliston, Ontario
L0M 1A0
Attention: Mr. Jeff Richardson

Dear Mr. Richardson:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval AE-0580.

It is noted that the six relay option board may include a maximum of four form C relays which can be used for energy pulses, either received or delivered. The remaining relays are form A and can be used for end-of-demand interval or load control contact closure. In the single and double relay versions, the relays are always form C and are approved for billing based on energy pulses, either received or delivered.

I am advised by the Electrical Metrology Laboratory that its evaluation of the proposed modification indicates that it may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modification is accepted as being included within the above-noted approval. All recipients of the notice of approval are being informed by copy of this letter.

Yours truly,

H.L. Fraser, Director
Electricity and Gas

cc: Approvals Mailing List

Canada



Industry
Canada

Industrie
Canada

Legal Metrology
Branch

Direction de la
métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa (Ontario)
K1A 0C9

Telephone: (613) 952-0635
FAX: (613) 952-1754

Téléphone: (613) 952-0635

File No.: 06565
Projet: AP-EL-94-0072
Date: 1994-12-20

Asea Brown Boveri Inc.
249 Dufferin Street
Alliston, Ontario
L0M 1A0
Attention: M. Jeff Richardson

Monsieur,

Nous accusons réception de l'avis de modification que vous nous avez envoyé récemment conformément à l'article 13, du Règlement sur l'inspection de l'électricité et du gaz, au sujet des appareils approuvés en vertu de l'avis d'approbation AE-0580.

Il est à noter que la carte facultative à six relais peut comprendre au plus quatre relais de forme C qui peuvent être utilisés pour les impulsions d'énergie reçues ou émises. Les autres relais sont de forme A et peuvent servir de fin de période d'intégration ou de fermeture du contact régissant la consommation. Dans les versions à relais simples et doubles, les relais sont toujours de forme C et sont approuvés à des fins de facturation en fonction des impulsions d'énergie reçues ou émises.

Après avoir étudié la modification proposée, le Laboratoire de l'électricité (métrologie) me signale que cette modification ne contrevient en rien aux dispositions de la Loi. En conséquence, la modification est acceptée et intégrée de facto dans l'avis d'approbation susmentionné. Tous ceux qui ont reçu l'avis d'approbation sont avisés de cette décision par une copie de la présente lettre.

Je vous prie d'agréer mes salutations distinguées.

H.L. Fraser, Directeur
Électricité et gaz

cc: Liste d'envoi des approbations

Canada