



**DEC 19 1996**

**NOTICE OF APPROVAL**

**AVIS D'APPROBATION**

Issued by statutory authority of the Minister of Industry  
for:

Émis en vertu du pouvoir statutaire du ministre de  
l'Industrie pour:

**TYPE OF DEVICE**

**TYPE D'APPAREIL**

Instrument Transformer: Current

Transformateur de mesure: courant

**APPLICANT**

**REQUÉRANT**

Corimpex International Inc.  
46 Ealing Drive  
Toronto, Ontario  
M2L 2R5

**MANUFACTURER**

**FABRICANT**

Associated Engineering Co.  
101 Kuhlman Boulevard  
Versailles, Kentucky 40383  
USA

**MODEL(S)/MODÈLE(S)**

**RATING / CLASSEMENT**

COF-250

400/800-5A  
100/200/300/400/500/600/700/800/1000-5A  
200/300/400/500/600/800/900/1000/1200-5A  
Accuracy rating/Classe de précision:  
0.3B1.8 for all ratios except/pour tout rapport sauf;  
200:5 : 0.3B0.5  
100:5 : 0.3B0.1

Rating Factor/Facteur de surcharge: 1.5

Frequency/Fréquence: 60 Hz

Nominal voltage class/Catégorie de tension nominale: 46 kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

#### **SUMMARY DESCRIPTION:**

The type COF current transformer is a porcelain post type, oil insulated, with the magnetic cores mounted in a metallic tank at the top.

#### **REVISION 1**

The purpose of this revision is to include additional ratios (100/200/300/400/500/600/700/800/1000-5A).

#### **REVISION 2**

The purpose of this revision is to include additional ratios (200/300/400/500/600/800/900/1000/1200-5A).

**REMARQUE:** Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

#### **DESCRIPTION SOMMAIRE:**


Les transformateurs de courant de type COF sont des transformateurs isolés à l'huile à support rigide en porcelaine dont les noyaux magnétiques sont installés dans un réservoir métallique placé au haut du support.

#### **RÉVISION 1**

Cette révision a pour but d'inclure des rapports additionnels (100/200/300/400/500/600/700/800/1000-5A) et (900/1200-5A).

#### **RÉVISION 2**

Cette révision a pour but d'inclure des rapports additionnels (200/300/400/500/600/800/900/1000/1200-5A).



COF-250

**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the Electricity and Gas Inspection Act. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local inspection office of Industry Canada.

Claude R. Bertrand, P.Eng.  
Manager  
Approval Laboratory Services

**APPROBATION:**

La conception, la composition, la construction et le rendement du(des) type(s) de compteurs identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellement, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la Loi sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. Sauf dans le cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local d'Industrie Canada.

Claude R. Bertrand, ing.  
Gérant  
Laboratoire des services d'approbation

Date: **DEC 19 1996**