



Measurement Canada  
An Agency of Industry Canada

Mesures Canada  
Un organisme d'Industrie Canada

APPROVAL No. - N° D'APPROBATION

**AE-1410 Rev. 1**

## NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry  
for:

## AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du ministre de  
l'Industrie pour:

### TYPE OF DEVICE

Instrument Transformer: voltage

### TYPE D'APPAREIL

Transformateur de mesure: tension

### APPLICANT

### REQUÉRANT

Ritz Instrument Transformers  
One Ritz Avenue  
Waynesboro, Georgia, 30830  
USA

### MANUFACTURER

### FABRICANT

Ritz Instrument Transformers  
One Ritz Avenue  
Waynesboro, Georgia, 30830  
USA

### MODEL(S)/MODÈLE(S)

### RATING/ CLASSEMENT

VEF 48-01

Accuracy class/Classe de précision: 0.3 WXY  
Frequency/Fréquence: 60Hz  
Voltage class/Catégorie de tension: 48kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

### SUMMARY DESCRIPTION:

The VEF 48-01 is a resin encapsulated voltage transformer.

### RATIO AND TAP

The following ratios and taps are approved for revenue metering:

Ratio Rapport	Tap Enroulement		Accuracy class Classe de précision	
27600-115V/69V-115V/69V	X <sub>1</sub> -X <sub>3</sub>	X <sub>2</sub> -X <sub>3</sub>	0.3WXY	0.3WXY
	Y <sub>1</sub> -Y <sub>3</sub>	Y <sub>2</sub> -Y <sub>3</sub>	0.3WXY	0.3WXY
24150-115V-115V	X <sub>1</sub> -X <sub>2</sub>		0.3WXY	
	Y <sub>1</sub> -Y <sub>2</sub>		0.3WXY	

### REVISION

**Original**

**Issued Date: 2005-07-13**

**Rev. 1**

The purpose of revision 1 was to include the 24150-115V ratio.

### RÉVISION

**Originale**

**Date d'émission : 2005-07-13**

**Rév. 1**

La révision 1 vise à inclure la rapport 24150-115V

## EVALUATED BY

David Lau, Original  
Senior Legal Metrologist  
Tel: (613) 952-0647  
Fax: (613) 9521754

Michael Rozeboom, Rev. 1  
Legal Metrologist  
Tel: (613) 957-0849  
Fax: (613) 952-1754

## NAMEPLATES AND MARKINGS



**ÉVALUÉ PAR**

David Lau, Originale  
Métrologiste légal principal  
Tél: (613) 952-0647  
Fax: (613) 952-1754

Michael Rozeboom, Rév. 1  
Métrologiste légal  
Tél. : (613) 957-0849  
Fax : (613) 952-1754

## **PLAQUES SIGNALÉTIQUES ET MARQUAGE**

Voltage Transformer					
Type VEF 4B-01	SN	Std. IEEE C57.13			
IC		Vn 48.3kv	PFN95	WV	Bz 250-kV
		Req E		Freq 60	Hz
Apri 48000KV/27600 A	Tap	X1-X3	X2-X3	Y1-Y3	Y2-Y3
ovf 1.73/1min.	Ysec(V)	115	69	115	69
Thermo Burden 1600 VA	Ratio	240:1	400:1	240:1	400:1
Year of Manuf.	Acs.	0.3%WT	0.3%WT	0.3%WT	0.3%WT
10	12				
9					
8					
7					
6					
5					
4					
3					
2					
1					
0					
10	12				
9					
8					
7					
6					
5					
4					
3					
2					
1					
0					

**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

**APPROBATION :**

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Original signed by:

Vuong Nguyen  
Senior Engineer – Electricity Measurement  
Engineering and Laboratory Services Directorate

Copie authentique signée par :

Vuong Nguyen  
Ingénieur principal – Mesure de l'électricité  
Direction de l'ingénierie et des services de laboratoire

Date: **2007-05-25**

Web Site Address / Adresse du site Internet:

<http://mc.ic.gc.ca>