



## NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry  
for:

## AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du ministre de  
l'Industrie pour:

### TYPE OF DEVICE

Instrument Transformer: Current

### TYPE D'APPAREIL

Transformateur de mesure : courant

### APPLICANT

### REQUÉRANT

Trench Limited  
Instrument Transformer Division  
390 Midwest Road  
Scarborough, ON  
M1P 3B5

### MANUFACTURER

### FABRICANT

Trench Limited  
Instrument Transformer Division  
390 Midwest Road  
Scarborough, ON  
M1P 3B5

### MODEL(S)/MODÈLE(S)

IOSK 245

### RATING/CLASSEMENT

Accuracy Class / Classe de précision : 0.3B1.8  
Rating factor / Facteur de surcharge : 3.0  
Frequency / Fréquence : 60 Hz  
Voltage class / Catégorie de tension: 245 kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

### **SUMMARY DESCRIPTION:**

The type IOSK 245 transformers are insulated post type. It is designed for outdoor use.

### **RATIO / TAP**

The following ratio is approved for revenue metering:

<b>Ratio Rapport</b>	<b>Tap Enroulement</b>	<b>Accuracy Class Classe de précision</b>
1000-5A	X <sub>1</sub> -X <sub>2</sub>	0.3B1.8

### **EVALUATED BY**

David Lau,  
Senior Legal Metrologiste  
Tel: (613) 952-0647  
Fax: (613) 952-1754

### **ÉVALUÉ PAR**

David Lau,  
Métrologue légal principal  
Tél: (613) 952-0647  
Fax: (613) 952-1754



		<b>TRENCH LIMITED</b>		MADE IN CANADA
<b>CURRENT TRANSFORMER IOSK 245</b>				
S.O.	: T067553	Year :	SER. No. :	
T range	: -30/+40°C	INSUL. OIL TYPE:	VOLTESSO N36	
U m	: 245 KV	OIL VOLUME:	90 L	WEIGHT : 470 kg
I <sub>dyn</sub>	: 100 KA PEAK	I <sub>th</sub> :	40 KA RMS 1 s	R.F. : 3.0
INS. LEV.	: 460/1050 KV	D.F. :	%	f <sub>N</sub> : 60 Hz
CSA CAN3-C13-M83				
I <sub>pn</sub> (A)	H1 - H2 1000			
Core	X			
	1-2			
K <sub>n</sub> (A/A)	1000:5			
Class	0.15B1.B AT 5% - 300% RATED CURRENT 0.3B1.B AT 1% - 5% RATED CURRENT			
MEASUREMENT CANADA APPROVAL:				

**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

**APPROBATION :**

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Original signed by Claude Renaud for:

Copie authentique signée par Claude Renaud pour :

Vuong Nguyen  
Senior Engineer – Electricity Measurement  
Engineering and Laboratory Services Directorate

Vuong Nguyen  
Ingénieur principal – Mesure de l'électricité  
Direction de l'ingénierie et des services de laboratoire

Date: **2006-12-06**

Web Site Address / Adresse du site Internet:  
<http://mc.ic.gc.ca>