



NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry
for:

TYPE OF DEVICE

Instrument Transformer: Current

APPLICANT

AREVA T&D Canada Inc.
1400 rue Industrielle
LaPrairie, Québec
Canada
J5R 2E5

MANUFACTURER

AREVA T&D,S.A.de C.V.
Calle 4 Norte No. 101
Parque Industrial Toluca 2000
C.P. 50200 Toluca, Edo., de Mexico

MODEL(S)/MODÈLE(S)

SDF-36

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du ministre de
l'Industrie pour:

TYPE D'APPAREIL

Transformateur de mesure: courant

REQUÉRANT

FABRICANT

RATING/ CLASSEMENT

2000-5-5A

Accuracy class / Classe de précision: 0.3B2.0

Rating factor / Facteur de surcharge: 1.0

Frequency / Fréquence: 60 Hz

Voltage class / Catégorie de tension: 25 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

SUMMARY DESCRIPTION:

The SDF-36 is a resin post type current transformer for outdoor use.

RATIO / TAP

The following ratio is approved for revenue metering:

Model Modèle	Report Ratio	Tap Enroulement	Accuracy Class Classe de précision	Rating factor Facteur de surcharge
SDF-36	2000-5A	X ₁ -X ₅ Y ₁ -Y ₅	0.3B2.0	1.0

EVALUATED BY

Michael Rozeboom
Legal Metrologist

REMARQUE: Cette approbation vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

DESCRIPTION SOMMAIRE:

Le SDF-36 est un transformateur de courant en résine pour usage extérieur.















RAPPORT/ENROULEMENT

Le rapport suivant est approuvé aux fins de facturation:

ÉVALUÉ PAR

Michael Rozeboom
Métrologiste légal

APPROVAL No. - N° D'APPROBATION

		CURRENT TRANSFORMER			
TYPE : SDF-36		25 / 50 / 150 kV STANDARD : CSA CAN3 C13 M83		FREQUENCY 60 Hz	
+o  o P1	o  o P2	PRIM. P1 - P2	I. ther. = 25 kA -1 sec. I. Prim. = 2 000 A	I. dyn. = 60 kA I. Sec. = 5 A	
SCHEMATIQUE DIAGRAM		SECONDARY TERMINALS	RATIO	ACCURACY	I cth. %
+o  o X1	o  o X2	o  o X3	o  o X4	o  o X5	X1 - X5 2 000/5 A 2.5 L400 100
+o  o Y1	o  o Y2	o  o Y3	o  o Y4	o  o Y5	Y1 - Y5 2 000/5 A 2.5 L400 100
PO # <u>EL11975</u> Industry Canada Approval number _____					
ATCO # _____ THE SECONDARY TERMINALS MUST BE SHORT CIRCUIT AND MUST BE CONNECTED TO THE GROUND					
*M.D. MANUFACTURE ORDER :			TOTAL WEIGHT : 110 Kg.		



APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

Original signed by:
Vuong Nguyen
Senior Engineer – Electricity Measurement
Engineering and Laboratory Services Directorate

APPROBATION :

APPROVAL No. - N° D'APPROBATION

AE-1539

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établies en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Copie authentique signée par :
Vuong Nguyen
Ingénieur principal – Mesure de l'électricité
Direction de l'ingénierie et des services de laboratoire

Date: **2007-10-01**

Web Site Address / Adresse du site Internet:
<http://mc.ic.gc.ca>