



Mesures Canada

**NOTICE OF APPROVAL**

**AVIS D'APPROBATION**

Issued by statutory authority of the Minister of Industry for:

Émis en vertu du pouvoir statutaire du ministre de l'Industrie pour:

**TYPE OF DEVICE**

**TYPE D'APPAREIL**

Instrument Transformer: Current

Transformateur de mesure: courant

**APPLICANT**

**REQUÉRANT**

Amran Inc.,  
10830 Kinghurst Drive  
Houston Texas  
USA  
77099

**MANUFACTURER**

**FABRICANT**

Narayan Powertech Pvt. Ltd. / Transtech Magnetics Pvt. Ltd  
Padra-Vadodara  
Padra, Gujarat  
INDIA

Amran Inc.,  
10830 Kinghurst Drive  
Houston Texas  
USA  
77099

**MODEL(S)/MODÈLE(S)**

**RATING/ CLASSEMENT**

BCT  
CT211-201

200-5A  
Accuracy class / Classe de précision: 0.3B0.1  
Rating factor / Facteur de surcharge: 1.5  
Frequency / Fréquence: 60 Hz  
Voltage class / Catégorie de tension: 0.7 kV

**NOTE:** This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

### SUMMARY DESCRIPTION:

The model CT211-201 is a window type current transformer.

### RATIO / TAP

The following ratios are approved for revenue metering:

Ratio Rapport	Tap Enroulement	Accuracy class Classe de précision	Rating Factor Facteur de surcharge
200-5A	X <sub>1</sub> -X <sub>2</sub>	0.3B0.1	1.5

### EVALUATED BY


Michael Rozeboom  
Legal Metrologist

### ÉVALUÉ PAR

Michael Rozeboom  
Métrologiste légal

### NAMEPLATE AND MARKINGS

### PLAQUE SIGNALÉTIQUE ET MARQUAGES

<b>AMRAN INC.</b> <b>CURRENT TRANSFORMER</b>	
CATALOG NUMBER: CT211-201	REF: ZZZZZZ
RATIO: 200/5	TRF = 1.50 30C
60 HZ	METERING CLASS: 0.3B0.1
0.6kV BIL 10kV	
SR. NO: YYYYYY	
AE-XXXX	
	
Made in India	

**APPROVAL:**

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

**ORIGINAL COPY SIGNED BY:**

Adnan Rashid  
Senior Engineer – Electricity Measurement  
Engineering and Laboratory Services Directorate

**APPROBATION :**

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

**COPIE AUTHENTIQUE SIGNEE PAR:**

Adnan Rashid  
Ingénieur principal – Mesure de l'électricité  
Direction de l'ingénierie et des services de laboratoire

Date: **2010-09-17**

Web Site Address / Adresse du site Internet:

<http://mc.ic.gc.ca>