



Mesures Canada

NOTICE OF APPROVAL

AVIS D'APPROBATION

Issued by statutory authority of the Minister of Industry for:

Émis en vertu du pouvoir statutaire du ministre de l'Industrie pour:

TYPE OF DEVICE

TYPE D'APPAREIL

Instrument Transformer: Current

Transformateur de mesure: courant

APPLICANT

REQUÉRANT

Siemens Canada Ltd.,
1550 Appleby Line
Burlington, Ontario
L7L 6X7

MANUFACTURER

FABRICANT

ABB Inc
P.O. Box 687
3022 NC Highway 43 North
Pinetops, North Carolina,
27864 USA

MODEL(S)/MODÈLE(S)

RATING/ CLASSEMENT

BCM
72-281-900-152

2000/1500/1200/400-5A
Accuracy class / Classe de précision: 0.3B1.8
Rating factor / Facteur de surcharge: 2.0
Frequency / Fréquence: 60 Hz
Voltage class / Catégorie de tension: 0.6 kV

NOTE: This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the Electricity and Gas Inspection Regulations. The following is a summary of the principal features only.

SUMMARY DESCRIPTION:

The model 72-281-900-152 is a bushing current transformer.

RATIO / TAP

The following ratios are approved for revenue metering:

Ratio Rapport	Tap Enroulement	Accuracy class Classe de précision	Rating Factor Facteur de surcharge
2000-5A	X ₁ -X ₅	0.3B1.8	2.0
1600-5A	X ₂ -X ₅		
1500-5A	X ₁ -X ₄		
1200-5A	X ₁ -X ₃		
1100-5A	X ₂ -X ₄		
800-5A	X ₂ -X ₃		

EVALUATED BY

Michael Rozeboom
Legal Metrologist

ÉVALUÉ PAR

Michael Rozeboom
Métrologiste légal

REMARQUE: Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du Règlement sur l'inspection de l'électricité et du gaz. Ce qui suit est une brève description de leurs principales caractéristiques.

DESCRIPTION SOMMAIRE:


Le modèle 72-281-900-152 est un transformateur de courant pour traversée.

RAPPORT / ENROULEMENT

Les rapports suivants sont approuvés aux fins de facturation:

NAMEPLATE AND MARKINGS

PLAQUE SIGNALÉTIQUE ET MARQUAGES

<h1 style="margin: 0;">SIEMENS</h1>					
Type BCM Bushing Current Transformer					
Shop Order	Frequency 60 Hertz	Acc. 2.5L400 @ 800:5/0.3B1.8 @ 2000:5	R.F. 2.0	Part No. 72-281-900-152	
Transformers this Part No. are Assembled on Terminals: NOTE: CSA 660044-1: 2007. 0.3B1.8 ACCURACY AT 800:5 AND UP.			Current Ratio	Turn Ratio	Secondary Taps
			300-5	60-1	X3-X4
Curve Sheet No. 72-281-909-452			400-5	80-1	X1-X2
 <p>Development of Winding Polarity mark adjacent to terminal "X1" indicates that the end of the terminal bushing opposite the breaker contacts and terminal "X1" have like polarity with any combination of taps. The tap numerically nearest "X1" has the same relative polarity as "X1".</p>			500-5	100-1	X4-X5
			800-5	160-1	X2-X3
			1100-5	220-1	X2-X4
			1200-5	240-1	X1-X3
			1500-5	300-1	X1-X4
			1600-5	320-1	X2-X5
2000-5	400-1	X1-X5			
Siemens Energy, Inc. MEASUREMENT CANADA APPROVAL			Jackson, MS		
Made in U.S.A. AE-XXXX			72-184-065-152		

APPROVAL:

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, marking, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the Electricity and Gas Inspection Regulations. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

Original copy signed by:

Adnan Rashid
Senior Engineer – Electricity Measurement
Engineering and Laboratory Services Directorate

APPROBATION :

La conception, la composition, la construction et le rendement du(des) type(s) de compteur(s) identifié(s) ci-dessus, ayant fait l'objet d'une évaluation conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, l'installation, le marquage, et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux prescriptions établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les prescriptions établis en vertu de l'article 18 du Règlement sur l'inspection de l'électricité et du gaz. Les exigences d'installation et d'utilisation sont définies dans les prescriptions établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada.

Copie authentique signée par :

Adnan Rashid
Ingénieur principal – Mesure de l'électricité
Direction de l'ingénierie et des services de laboratoire

Date: **2012-10-10**

Web Site Address / Adresse du site Internet:
<http://mc.ic.gc.ca>