



Measurement
Canada

An Agency of
Industry Canada

Mesures
Canada

Un organisme
d'Industrie Canada

APPROVAL No. - N° D'APPROBATION

AE-2207

NOTICE OF APPROVAL

Issued by statutory authority of the Minister of Industry for:

AVIS D'APPROBATION

Émis en vertu du pouvoir statutaire du ministre de l'Industrie pour:

TYPE OF DEVICE

Instrument Transformer: Current

TYPE D'APPAREIL

Transformateur de mesure: courant

APPLICANT / REQUÉRANT

ALSTOM Grid Messwandler GmbH
Bauernallee 27
Ludwigslust
D-19288 Germany

MANUFACTURER / FABRICANT

ALSTOM Grid Messwandler GmbH
Bauernallee 27
Ludwigslust
D-19288 Germany

MODEL(S) / MODÈLE(S)

OSKF 800

MANUFACTURER'S RATING / CLASSEMENT DU FABRICANT

Rated Ratio(s) / Rapport(s) nominal(aux)	2000-5-5-5-5A
Frequency / Fréquence	60 Hz
Voltage Class / Catégorie de tension	800 kV

NOTE : This approval applies only to meters, the design, composition, construction and performance of which are, in every material respect, identical to that described in the material submitted, and that are typified by samples submitted by the applicant for evaluation for approval in accordance with sections 13 and 14 of the *Electricity and Gas Inspection Regulations*. The following is a summary of the principal features only.

SECTION 1 – Ratings and Specifications

Approved Model Designations / Désignations de modèle approuvé				
The model OSKF 800 is a post type current transformer. Le modèle OSKF 800 est un transformateur de courant de type poteau.				
<i>Transformers are approved for revenue metering only for the characteristics identified below:</i> <i>Les transformateurs sont approuvés aux fins de facturation seulement pour les caractéristiques indiquées ci-dessous:</i>				
Rated Ratio / Rapport nominal	Approved Primary and Secondary Current / Courant primaire et secondaire approuvé	Approved Tap / Enroulement approuvé	Accuracy Class / Classe de précision	Rating Factor / Facteur de surcharge
2000-5-5-5-5A	2000-5A	X ₁ -X ₂	0.3B1.8	1.0


REMARQUE : Cette approbation ne vise que les compteurs dont la conception, la composition, la construction et le rendement sont identiques, en tout point, à ceux qui sont décrits dans la documentation reçue et pour lesquels des échantillons représentatifs ont été fournis par le requérant aux fins d'évaluation, conformément aux articles 13 et 14 du *Règlement sur l'inspection de l'électricité et du gaz*. Ce qui suit est une brève description de leurs principales caractéristiques.

PARTIE 1 – Classements et caractéristiques

SECTION 2 – Nameplate and Photos

PARTIE 2 – Plaque signalétique et photos

TYPE OSKF 800 SK5		YEAR OF MANUFACTURE 2016		CURRENT TRANSFORMER	
INSULATION LEVEL				ALSTOM	
SYSTEM VOLTAGE		RATED POWER FREQUENCY WITHSTAND VOLTAGE		SERIAL NUMBER —	
FOR EQUIPMENT		IMPERIAL IMPULSE WITHSTAND VOLTAGE		ORDER NUMBER 3080-4500784384	
800 kV		975 kV		PRIMARY CURRENT (A) 2000	
E		F _r : Cl II		SECONDARY CURRENT (A)	
		60 Hz		5 5 5 5 5	
		I _{th}		2000 A 45	
		I _{th}		80 kA	
		I _{dyn}		130 kA	
WEIGHT				R _p 1,0 R _e 1,0 R _p 1,0 R _e 1,0 R _p 1,0	
WEIGHT OF OIL				R _{ct} <1,5Ω R _{ct} <1,5Ω R _{ct} <0,78Ω R _{ct} <1,5Ω R _{ct} <1,5Ω	
VOLUME OF OIL				V1 - V2 W1 - W2 X1 - X2 Y1 - Y2 Z1 - Z2	
TYPE OF OIL:		—		TEMPERATURE RANGE -50° / +40°C	
		CAN/CSA-C60044-1		M.C. CERTIFICATION NUMBER:	
MANUFACTURED BY ALSTOM GRID MESSWANDLER GMBH LUDWIGSLUST, GERMANY					
* 193893204 No Description and Installation Instruction: OTD-0709					



SECTION 3 – Original and Revisions

PARTIE 3 – Originale et Révisions

Original / Originale	Issued Date / Date d'émission	Evaluator / Évaluateur
	2016-01-18	Ray Kandalaf Senior Legal Metrologist / Métrologiste légal Principal

SECTION 4 – Approval

The design, composition, construction and performance of the meter type(s) identified herein have been evaluated in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. Approval is hereby granted accordingly pursuant to subsection 9(4) of the said Act.

The sealing, markings, installation, use and manner of use of meters are subject to inspection in accordance with regulations and specifications established under the *Electricity and Gas Inspection Act*. The sealing and marking requirements are set forth in specifications established pursuant to section 18 of the *Electricity and Gas Inspection Regulations*. Installation and use requirements are set forth in specifications established pursuant to section 12 of the Regulations. Verification of conformity is required in addition to this approval for all metering devices excepting instrument transformers. Inquiries regarding inspection and verification should be addressed to the local office of Measurement Canada.

PARTIE 4 – Approbation

La conception, la composition, la construction et la performance du(des) type(s) de compteur(s) identifié(s) ci-dessus ayant fait l'objet d'une évaluation conformément au Règlement et aux normes établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*, la présente approbation est accordée en application du paragraphe 9(4) de ladite Loi.

Le scellage, le marquage, l'installation et l'utilisation des compteurs sont soumis à l'inspection conformément au Règlement et aux normes établis aux termes de la *Loi sur l'inspection de l'électricité et du gaz*. Les exigences de scellage et de marquage sont définies dans les normes établies en vertu de l'article 18 du *Règlement sur l'inspection de l'électricité et du gaz*. Les exigences d'installation et d'utilisation sont définies dans les normes établies en vertu de l'article 12 dudit règlement. En plus de cette approbation et sauf dans les cas des transformateurs de mesure, une vérification de conformité est requise. Toute question sur l'inspection et la vérification de conformité doit être adressée au bureau local de Mesures Canada

Original copy signed by:

Adnan Rashid
Senior Engineer – Electricity Measurement
Engineering and Laboratory Services Directorate

Copie authentique signée par :

Adnan Rashid
Ingénieur principal – Mesure de l'électricité
Direction de l'ingénierie et des services de laboratoire

Date: **2016-01-18**

Web Site Address / Adresse du site Internet:
<http://mc.ic.gc.ca>