



Date: 2012-06-07

File number: 26681-AP-AE-12-0022

## **MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices**

### **Type of Device**

Electricity Meter: Energy

### **Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An Agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

### **Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

### **Approval Numbers**

AE-1665

### **Applicant**

Triacta Power Technologies, Inc.  
Box 582, 7 Mill Street  
Almonte, Ontario  
K0A 1A0

### **Description of Modifications**

The addition of the RS-485 interface has been approved.

### **Original copy signed by:**

Greg Neff

Acting Laboratory Manager - Electricity Measurement



Date: 2012-06-07

Dossier: 26681-AP-AE-12-0022

## **LETTRE D'ACCEPTATION DE MODIFICATION (LAM)** **pour** **Compteurs et Appareils Approuvés**

### **Type d'Appareil**

Compteurs Électrique: Énergie

### **Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

### **Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivants:

### **Numéros d'approbation**

AE-1665

### **Requérant**

Triacta Power Technologies, Inc.  
Box 582, 7 Mill Street  
Almonte, Ontario  
K0A 1A0

### **Descriptions des modifications**

L'addition de l'interface RS-485 a été approuvée.

### **Copie authentique signée par:**

Greg Neff

Gestionnaire de laboratoire par intérim- Mesure de l'électricité