



Measurement  
Canada

An Agency of  
Industry Canada

Mesures  
Canada

Un organisme  
d'Industrie Canada

MAL No. - N° De LAM  
**MAL-E365**

Date: 2014/05/12

File Number: AP-AE-13-0176

## **Modification Acceptance Letter (MAL) for Approved Meters and Devices**

### **Type of Device**

Electricity Meters: Energy and Demand

### **Purpose**

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from Measurement Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

### **Scope**

The modifications described in this letter affect meters identified in the following Notices of Approval:

### **Approval Numbers**

AE-1641  
AE-1723  
AE-1967

### **Applicant**

Landis+Gyr Inc.  
2800 Duncan Road  
Lafayette, IN  
47904

### **Description of Modifications**

Firmware version 9.10 has been released for the Gridstream RF (0746) and the Gridstream RF (0864) communication modules.

### **Original copy signed by:**

Hassan Lahdili  
Laboratory Manager - Electricity



Measurement  
Canada

An Agency of  
Industry Canada

Mesures  
Canada

Un organisme  
d'Industrie Canada

MAL No. - N° De LAM  
**MAL-E365**

Dossier: AP-AE-13-0037

éDate: 2014/05/12

## **Lettre d'acceptation de modification (LAM) pour les compteurs et appareils approuvés**

### **Type d'appareil**

Compteurs d'électricité: énergie et puissance

### **Objet**

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

### **Portée**

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivants :

### **Numéros d'approbation**

AE-1641  
AE-1723  
AE-1967

### **Requérant**

Landis+Gyr Inc.  
2800 Duncan Road  
Lafayette, IN  
47904

### **Description des modifications**

La version 9.10 de logiciel a été émise pour les modules de communications de Gridstream RF (0746) et de Gridstream RF (0864).

### **Copie authentique signée par :**

Hassan Lahdili  
Gestionnaire du laboratoire d'électricité