



Measurement Canada
An Agency of Industry Canada

Mesures Canada
Un organisme d'Industrie Canada

MAL No. - N° De LAM

MAL-E104

Date: December 13, 2005

File number: 26681-AP-AE-05-
0133

MODIFICATION ACCEPTANCE LETTER (MAL) FOR Approved Meters and Devices

Type of Device

Instrument Transformer: Current

Purpose

The purpose of this letter is to convey details of modifications to meters which have previously received approval of type recognition from An agency of Industry Canada. These modifications have been evaluated by the Approval Services Laboratory in accordance with national requirements and shall be considered to be included within the scope of the originally issued Notices of Approval specified in this document and any subsequent revisions to these Notices of Approval.

Scope

The modifications described in this letter affect meters identified in the following Notices of Approval:

Approval Numbers

AE-1426

Applicant

Electromech Co. Ltd.
2529 Shaughnessy Street,
Port Coquitlam ,BC,
V3C 5Z9

Description of Modifications

The voltage class is 27.5 kV instead of 15 kV.

Original signed by :

Claude G. Renaud
Technical Coordinator – Electricity Measurement



Measurement Canada
An agency of Industry Canada

Mesures Canada
Un organisme d'Industry Canada

MAL No. - N° De LAM

MAL-E104

Date: 13 décembre 2005

Dossier: 26681-AP-AE-05-0133

LETTRE D'ACCEPTATION DE MODIFICATION (LAM)
pour
Compteurs et Appareils Approuvés

Type d'Appareil

Transformateur de mesure: courant

Objet

La présente lettre vise à expliquer les détails des modifications apportées aux compteurs dont le type a déjà été approuvé par Mesures Canada. Ces modifications ont été évaluées par le Laboratoire des services d'approbation en conformité aux exigences nationales et doivent être considérées comme faisant partie de la portée des avis d'approbation d'origine énumérés dans le présent document et de toutes leurs révisions subséquentes.

Portée

Les modifications décrites dans la présente lettre s'appliquent aux compteurs visés par les avis d'approbation suivant:

Numéros d'approbation

AE-1426

Requérant

Electromech Co. Ltd.
2529 Shaughnessy Street,
Port Coquitlam ,BC,
V3C 5Z9

Descriptions des modifications

La catégorie de tension est 27.5 kV au lieu de 15 kV.

Copie authentique signée par :

Claude G. Renaud
Coordonnateur technique – Mesure de l'électricité