



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-2-1

Ottawa, August 14, 1975

LANDIS & GYR "K1" TIME IMPULSE STORAGE ATTACHMENT

This Notice constitutes an addition to Notice of Approval E-2 which remains in effect.

Apparatus

Duration of Contact Closures	700 milliseconds
Time Spacing of Contact Closures	16.1 seconds
Timing Periods	5, 10, 15, 20, 30, 60 minutes
Supply to Synchronous Motor	115, 120, 240 and 120/240 volts 60 Hz

This addition permits the use of "K1" time impulse storage attachment in place of the "K" time impulse storage attachment on approved Landis & Gyr Time Switches.

The "K1" is a modified version of the "K" and performs exactly the same function.

Approval granted to:

Landis & Gyr Ltd.,
2063 Chartier Street,
Dorval, Quebec

J.L. Armstrong,
Chief, Standards Laboratory,
Metrology and Laboratory Services.

D.L. Smith,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services.

Ref: GL 1145-57/L1-818