



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-16-1

OTTAWA November 27, 1974

SANGAMO TYPES "CJ3A" AND "CJ3S" SINGLE PHASE
WATTHOUR METERS

This amendment covers the use of U.S.-
manufactured replacement electromagnets for
types CJ3A and CJ3S watthour meters.

The replacement electromagnet is similar
in appearance to the original except that the
power factor adjustment has been replaced by a
soldered wire lag loop. The support bracket
for the light load adjustment has also been
slightly modified.

Approval granted to:

Sangamo Company Ltd.,
Toronto, Ontario.

J. L. Armstrong,
Chief, Standards Laboratory,
Metrology and

D. L. Smith,
Chief, Electricity & Gas Division,
Laboratory Services.

Ref: GL 1145-57/S2-887