



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

E-21

OTTAWA May 20, 1966

NOTICE OF APPROVAL
FOR

CANADIAN GENERAL ELECTRIC TYPES "VA-63A" and "VA-63S" 2-ELEMENT
AND "VA-65A" and "VA-65S" 2 1/2-ELEMENT Y POLYPHASE VARHOUR METERS

Apparatus

2-Element


Current Range	0.12-10 amperes				
Voltages	120	240	345	480	600
Varhour disc constant (Kh)	1.2	2.4	3.6	4.8	6.0
(1) Single Phase -					
(2) Watthour disc constant	0.693	1.386	2.079	2.771	3.464
(2) Test constant	.577 for all ratings				
Register ratio - 4 dial x 1 with test dial	166-2/3	83-1/3	55-5/9	41-2/3	33-1/3

2 1/2-Element Y

Current Range	0.12-10 amperes	
Voltage	208	
Varhour disc constant (Kh)	1.8	
(1) Single Phase -		
(3) Watthour disc constant	3.12	
(3) Register Test Constant	1.732	
Register Ratio 4 & 5 dial x 1 with test dial	111-1/9	
Frequency	60 Hz all ratings	
Detent	Approved with and without, all ratings	

- The single phase watthour disc constant marked on the nameplate is the value to be used when verifying these meters on single phase.

CANADIAN GENERAL ELECTRIC TYPES "VA-63" and "VA-63S" 2-ELEMENT
AND "VA-65A" and "VA-65S" 2½-ELEMENT Y POLYPHASE VARHOUR METERS



2. The single phase test constant marked on the nameplates of the type VA-63 as "Amp. x 0.577" is to be used for two purposes when verifying this type -
 - (1) As a multiplier for the prescribed test currents. For example, if one of the prescribed test currents is 5 amperes, the single phase test current that is to be applied to produce a torque equivalent to that of a watt-hour meter of the same rating would be 5×0.577 or 2.89 amperes.
 - (2) As a multiplier to be applied to the register reading when dial-testing on single phase. The register ratio (Rr) matches the disc revolutions in varhours, and therefore when testing on single phase where the disc constant has been converted to watt-hours, it is necessary to apply this multiplier to the register reading as follows - one revolution of the test dial is equivalent to 1 kilovarhour so that the rotating standard will record during that time 1000×0.577 or 577 watt-hours.
3. The register test constant of 1.732 is not marked on the nameplate of the type VA-65. It is the ratio between the single phase disc constant of 3.12 and the polyphase varhour constant of 1.8.

As in the case of the VA-63, the register ratio matches the disc revolutions in varhours, so that when testing on single phase where the disc constant has been converted to watt-hours, one revolution of the test dial or 1 kilovarhour requires that the rotating standard record during that time 1000×1.732 or 1732 watt-hours.

Description

The types VA-63 and VA-65 kilovarhour meters are basically the same as the types V-63 and V-65 watt-hour meters respectively.

The type VA-63 differs from the type V-63 in that it has two separate current coils on each electromagnet, one having twice the number of turns of the other and in having the two electromagnets cross-connected.

The type VA-65 is similar to the type V-65 in that it also has a split coil for "B" current, but differs in that the voltage coils are wound for 208 volts and are intended to be connected in service "line-to-line".


Verification of the type VA-65 will be done with 208 volts applied to both meter and standard.

When verifying the two element VA-63 on single phase, because of the direction in which the current coils are wound, it will be necessary to reverse the connections to the voltage coil of the right-hand element in order to produce forward rotation of the disc.


CANADIAN GENERAL ELECTRIC TYPES "VA-63" and "VA-63S" 2-ELEMENT
AND "VA-65A" and "VA-65S" 3-ELEMENT Y POLYPHASE VARHOUR METERS

CONNECTION DIAGRAMS 53-1 50742


CANADIAN GENERAL ELECTRIC
COMPANY LIMITED
MONTREAL, QUEBEC, CANADA




VA-65A POLYPHASE VARHOUR METER
4 WIRE Y 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE A-B-C)




VA-63A POLYPH. VARHOUR METER
4 WIRE Y 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE A-B-C-N)




VA-63A POLYPH. VARHOUR METER
3 WIRE Δ 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE A-B-C)




VA-65A POLYPH. VARHOUR METER
4 WIRE Y 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE C-B-A-N)




VA-65A POLYPH. VARHOUR METER
4 WIRE Y 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE A-B-C-N)




VA-65A POLYPHASE VARHOUR METER
4 WIRE Y 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE A-B-C)




VA-63A POLYPH. VARHOUR METER
3 WIRE Δ 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE C-B-A)



VA-63A POLYPH. VARHOUR METER
4 WIRE Y 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE C-B-A-N)



VA-65A POLYPH. VARHOUR METER
3 WIRE Δ 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE C-B-A)



VA-63A POLYPH. VARHOUR METER
3 WIRE Δ 3 PH. WITH CURR. TRANS.
(PHASE SEQUENCE A-B-C)

The type VA-63 may be used to meter the reactive energy in a 3-phase 4-wire Y circuit if the current coils are fed from the secondaries of three current transformers connected in delta, similar to the connections of a 2-element watt-hour meter.

In this application, the connections differ from those of the 2-element watt-hour meter in that - (a) the current to element "A" and (b) the potential to element "C" of the watt-hour meter are connected in reverse polarity.

As these watt-hour meters will measure correctly the reactive energy in a circuit only when connections are made in accordance with phase rotation, the Company has prepared and will include with every watt-hour meter shipped, a print showing the correct connections for various applications.

This print is reproduced on this circular. A more complete description of the operation of these watt-hour meters will be found in Technical Bulletin No. 7.

Some type VA-63 watt-hourmeters may be encountered which do not have the single phase test constant "Amp. x 0.577" marked on their nameplates.

These meters are to be treated no differently from those that have nameplates on which this marking appears.

Approval granted to: The Canadian General Electric Company Limited,
1130 Boulevard Charest,
Quebec 8, Que.

W.J.S. Fraser
W.J.S. Fraser,
Chief, Standards Laboratory,
Standards Branch.

K. Cryer
K. Cryer,
Chief, Electricity & Gas Division,
Standards Branch.

Ref: SL-100-801Q