



DEPARTMENT OF TRADE AND COMMERCE
STANDARDS BRANCH

E-27

OTTAWA March 2, 1966.

NOTICE OF APPROVAL

FOR

CANADIAN WESTINGHOUSE TYPES "D2A", "D2S" AND "D3S" SINGLE PHASE
WATTHOUR METERS

Current Range (amperes)	Volts	Kh	Wire	Register Ratio (clock & cyclometer) (1)			
				4-dial x 1	4-dial x 10	5-dial x 1	4/5-dial x 1 (5)
.12-10 (7)	115-120	.18	2	555-5/9	--	--	--
	230-240	.36	2	277-7/9	--	--	--
.75-100 (1.0-100) (2)	230-240	3.6	3	27-7/9	277-7/9	--	--
" VC (6)	230-240	3.6	3	27-7/9	277-7/9	--	--
1.5-100/.75-100 (3)	115/230	3.6	2/3	27-7/9	277-7/9	--	--
(1.0-100) (2)	120/240						
2-100/200 (4)	230-240	7.2	3	--	138-8/9	13-8/9	13-8/9
2-100/200 VC (6) (8)	230-240	7.2	3	--	138-8/9	13-8/9	13-8/9
2-200	230-240	7.2	3	--	138-8/9	13-8/9	13-8/9
2-200 VC (6) (6)	230-240	7.2	3	--	138-8/9	13-8/9	13-8/9
Frequency	60 Hz all ratings						

- (1) This cyclometer register received approval under S-EA.606 and E17
- (2) The nameplate marking of .75-100 ampere meters has been changed to conform to the new CSA standard of 1.0-100 amperes. There is no change in the meter and either nameplate may be encountered.
- (3) The 115/230V 2/3-wire marking indicates the 2-wire/3-wire meter receiving approval under circular SD-EA.307 of August 19, 1957.

CANADIAN WESTINGHOUSE TYPES "D2A", "D2S" AND "D3S" SINGLE PHASE
WATTHOUR METERS
