



Consommation
et Corporations Canada

Consumer and
Corporate Affairs Canada

Direction de la
Métrologie légale

Legal Metrology
Branch

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file Votre référence

Legal Metrology Laboratories
Telephone: (613) 990-8621

Our file Notre référence

O6565-S2-6
June 27, 1985
AML-E-11

Sangamo Canada
Division of Schlumberger Canada Limited
215 Laird Drive
Toronto, Ontario
M4G 3X1
Attention: Mr. M. Purc, P. Eng.
Director of Engineering

Dear Mr. Purc:

This letter is in response to your letter dated June 21, 1985, regarding the modification to the types KY, KYL, KYW, KYQ, KYR and K300 damping magnet assemblies by substituting a stainless steel anchor spring for the two bolts, nuts and springs formerly used to secure the adjustment plates, which are currently approved in Notices of Approval E-60, E-65, E-66, E-71, E-96, E-137, E-181 and subsequent dash numbers to these basic approvals. I am advised that the Electrical Laboratory has evaluated this modification and concluded that it may be regarded as insignificant, in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, pursuant to the authority delegated to me under the said Act;

1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C. 1978, chapter 561, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned subsection, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by copy of this letter.

Yours truly

W.R. Virtue
Chief

cc: Mailing List (Electrical Approvals)

Canada