



Consumer and
Corporate Affairs
Canada

Legal Metrology

Consommation
et Corporations
Canada

Métrie Légale

E-60-5

Approval No. d'approbation

Ottawa

1982/02/24

NOTICE OF APPROVAL – AVIS D'APPROBATION

Approval Granted To:

Approbation accordée à:

Sangamo Canada
215 Laird Drive
Toronto, Ontario
M4G 3X1

W.R. Virtue

Acting Chief
Legal Metrology Laboratories
Legal Metrology Branch
Standards Building
Tunney's Pasture, Holland Ave.,
OTTAWA, Ontario
K1A 0C9

Chef intérimaire
Laboratoires de la métrologie légale
Direction de la métrologie légale
Edifice des normes
Parc Tunney, Avenue Holland
OTTAWA, Ontario
K1A 0C9

SANGAMO TYPE KY POLYPHASE WATTHOUR
REGISTER X 100 MULTIPLIER

This notice constitutes an addition to Approval Notice E-60, of September 1, 1967, and allows the use of a register with a register ratio of 208 1/3, 4 dials x 100 multiplier. These registers will be used on type KY watthour meters, 480 volts, 2 element, 2.5 --- 200 ampere, Kh 57.6. The registers will have test dials.

MINUTERIE SUR WATTHEUREMETRE POLYPHASE DE
TYPE SANGAMO KY, A MULTIPLICATEUR 100

Cet avis constitue un ajout à l'avis d'approbation E-60, en date du 1er septembre 1967, et autorise l'utilisation d'une minuterie ayant une constante de 208 1/3, 4 cadrans à multiplicateur 100. Ces minuteries seront installées sur des watt-heuremètres de type KY, de 480 volts, à deux éléments, de 2.5 à 200 ampères, Kh 57.6. Elles comporteront des cadrans de contrôle.

Reference No.: G6565-S2-10

No. de référence: G6565-S2-10