



Consumer and
Corporate Affairs

Consommation et
corporations

Standards

Normes

NOTICE OF APPROVAL
AVIS D'APPROBATION

E-63-1

Ottawa, February 11, 1977


Sangamo Type "WY-" Polyphase Thermal KW Demand Meters


This notice constitutes an addition to Notice of Approval E-63-1 and covers the optional fitting of a reverse power flow stop to type "WY-" KW demand meters.

The stop consists of a flat metal bar extending between the die cast thermal elements, secured at each end by the thermal element mounting screws. An angled protrusion on the bar is contacted by the tail of the driving pointer, preventing an off scale deflection below zero.

Approval granted to:

Sangamo Company Limited
Toronto, Ontario


J. L. Armstrong, P. Eng.
Chief,
Standards Laboratory


D. L. Smith, P. Eng.
Chief
Electricity & Gas Division

Metrology & Laboratory Services

Ref: G6565-S2-2