



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

NOTICE OF APPROVAL

E-78-2

OTTAWA January 22, 1973.

WESTINGHOUSE TYPES "WR-2C" AND "WR-4C" DEMAND RECORDERS

This approval covers additions to the ratings embraced under E-78-1. E-78-1 remains in effect.

1. The use of P-2 and P-3 surface mounted cases.
2. An increase in the maximum number of input pulses per channel to 1500 per 15 minute interval, 3000 per 30 minute interval and 6000 per 60 minute interval.
3. Addition of 20, 30 and 60 minute demand intervals except WR-2C which is 15 and 30 minutes only.
4. The addition of 1500 and 3000 pulse demand scales on type WR-2C.
5. Battery carry-over is now optional.

Approval granted to:

Canadian Westinghouse Company Limited,
Hamilton, Ontario.

(for) J.S.T. Swanson, P. Eng.,
Chief, Standards Laboratory,
Standards Branch.

W.J.S. Fraser
Chief, Electricity and Gas Division,
Standards Branch.

Ref: GL 1145-57/C3-986(L)
L 1145-57/C3-986