



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-78-3

OTTAWA April 26, 1974

Westinghouse Type WR-2C Demand Recorder

This Notice is an addition to E-78-1 which otherwise remains in effect.

Approval is hereby granted to modify any type WR-2C recorder fitted with a demand register so that it may serve as a "Master" recorder. The modification shall only involve disconnecting from the terminal block (Fig. 21, instruction book 42-565 WR-1) the yellow leads from the reed switch shown as DS3 in Aux. No. 2 of Fig. 8. These leads from the reed switch are then reconnected to terminals T1 and T2 as in the original approval for "Master" connection and as shown in Aux. No. 4 of Fig. 8. The demand functioning of the register shall be disabled by removing the indicating demand pointer.

Approval granted to:

Westinghouse Canada Ltd.,
Hamilton, Ontario.

J. L. Armstrong,
Chief, Standards Laboratory,
Metrology and Laboratory Services.

W.J.S. Fraser,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services.

Ref: GL 1145-57/C3-986
G 1145-57/C3-986