



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file V^{otre} référence

Legal Metrology Laboratories
Telephone: (613) 952-0615

Our file N^{otre} référence

O6565-C3-7
September 24, 1986
AML-E-22

Westinghouse Canada Inc.
Box 510
Hamilton, Ontario
L8N 3K2

Attention: Mr. S.A. Jafer, P. Eng.
EC & DP Division

Dear Mr. Jafer:

This is in response to your letter dated September 9, 1986, regarding the optional fitting of one piece polycarbonate plastic covers to single and polyphase watt-hour meters of D4S and D5S types, currently approved in Notices of Approval E-82, E-82-2, E-122, E-122-1, E-122-2, E-122-3, E-122-4, E-122-5, E-133, E-133-1, E-154, E-194, E-194-1, E-195, E-211 and E-212, and your intention to make available glass covers as a standard feature.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as insignificant in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

1. your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue
Chief

cc: Mailing List (Electrical Approvals)

Canada