



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file *Votre référence*

Legal Metrology Laboratories
Telephone: (613) 990-8621

Our file *Notre référence*

O6565-C2-7
February 25, 1986
AML-E-17

Canadian General Electric
1130 West Charest Blvd.
Québec, P.Q.
G1N 2E2

Attn: Mr. Jean-Yves Bérubé, P. Eng.
Engineering Department

Dear Mr. Bérubé:

This is in response to your letter dated February 14, 1986, regarding the proposed modification to the type I-70A watt-hour meters which are currently approved in Notices of Approval E-88-1, E-88-2, E-88-6 and E-88-8. I am advised that the Electrical Laboratory has evaluated the proposed modification (i.e.: removal of the seal pans) and has concluded that, since wax is no longer the sealing medium used by departmental inspectors, the seal pans are redundant.

Accordingly, the modification is hereby accepted as being an immaterial one and hence included within the existing approvals.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

W.R. Virtue
Chief,
Legal Metrology Laboratories

WRV:kl
cc: Mailing List (Electrical Approvals)