



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-88-7

Ottawa, April 30, 1980

CANADIAN GENERAL ELECTRIC TYPE I-70S  
SINGLE PHASE WATT HOUR METER FOR USE  
ON SINGLE PHASE 2-WIRE 120 VOLT 60 Hz  
CIRCUITS

Current Range	1.0 - 100 amperes
Voltage	120 volts
Frequency	60 Hz
Wire	2
Disc Constant Kh	1.8 watt hours per rev.
Register Ratio	55 5/9 4-Dial x 1 clock with test dial

Description

The watt hour meters covered by this Approval Notice have the same exterior dimensions and appearance as the previously approved I-70S single phase watt hour meters.

These meters are approved as a replacement meter on existing 2 wire 120V installations where it is not feasible to replace service entrance conductors and equipment.

The wiring connections are the standard connections for a single phase, 2 wire, S-base, self-contained meter.

Approval granted to: Canadian General Electric Company Limited,  
1130 West Charest Blvd.,  
Quebec, P. Q.  
G1N 2E2

D. L. Smith, Chief,  
Electricity and Gas Division,  
Legal Metrology Branch.

Ref: G6565-C2-7