



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-95-1

OTTAWA October 16, 1974.


LANDIS & GYR TYPE "KYB1-" TIME SWITCH


This addition permits the use of an additional contact, designated 'g' with this approved switch. The 'g' contact is similar to the contact 'k' and is always used in combination with 'k'. Operation is in the same way as contact 'k' through an extended shaft and a 1:1 ratio gear, but the gears are set in such a way that the 'g' contact operates 2 to 3 seconds after opening of the 'k' contact.

This Notice constitutes an addition to Notice of Approval E-95 which remains in effect.

Approval granted to:

Landis & Gyr Inc.,
2063 Chartier Street,
Dorval 760, Quebec.


J. L. Armstrong, P. Eng.,
Chief, Standards Laboratory,


D. L. Smith, P. Eng.,
Chief, Electricity & Gas Division,
Metrology and Laboratory Services.

Ref: GL 1145-57/L1-818