



Department of consumer and corporate affairs / Ministère de la consommation et des corporations



STANDARDS BRANCH - DIRECTION DES NORMES

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-111-2

OTTAWA March 6, 1975

FERRANTI-PACKARD TYPES B5A AND B5S
SINGLE-PHASE WATTHOUR METERS

This Notice is an appendix to Notice of Approval E-111 which remains in force.

This Notice covers a change in the register. The change consists of replacing the worm and worm wheel second reduction with a crown gear. Except for a few related parts the remainder of the register remains unchanged. New and old style registers are interchangeable.

Approval granted to:

Ferranti-Packard Ltd.,
Dieppe Road,
St. Catharines, Ont.

J. L. Armstrong, P. Eng.,
Chief, Standards Laboratory,

D. L. Smith, P. Eng.,
Chief, Electricity & Gas
Division,

Metrology and Laboratory Services.

Ref: GL 1145-57/F2-881