



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-116-1

Ottawa, May 28, 1979

SANGAMO TYPE "K2X" SINGLE PHASE, 3 WIRE, WATTHOUR METER

This notice constitutes an addition to Approval Notice E-116, dated November 21, 1972.

Current Range:	1.0 - 100 amperes
Voltage:	240 volts
Frequency:	60 Hz
Wire:	3
Disc Constant (Kh):	3.6
Registers:	4 dial clock Rr 27 7/9 with test dial
	5 dial clock Rr 27 7/9 with test dial
	4 dial clock Rr 277 7/9 with test dial

Description

The Type "K2X", 3 wire meter is identical in construction to the "K2X" 2 wire meter, except the potential coil is 240 volts and the current coils are the conventional 3 wire, 2 coil design. The "K2X", 100 amp, 240 volt, 3 wire meter element is also identical in design to the K2A, 100 amp, 240 volt, 3 wire meter element, Approval Notice E-121 of February 9, 1973, except the element is mounted in a smaller enclosure and the terminal block is equipped with only one test link.

The Letter "X" in the type designation is to denote the base design as being different from the conventional type "A" base.

Approval granted to:

Sangamo Company Limited  
Toronto, Ontario

D. L. Smith, P.Eng.,  
Chief, Electricity & Gas Division  
Legal Metrology Branch

Ref: G 6565-S2-7

