



**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-122-2

Ottawa, December 3, 1976

WESTINGHOUSE CANADA TYPE "D4S-5" 200 AMP
SELF-CONTAINED POLYPHASE WATTHOUR METER

This Notice is an addition to Approval E-122 to include the 200A rating. E-122 remains in effect.

TYPE D45-5

<u>Current Range</u> <u>Amperes</u>	<u>Voltage</u>	<u>Wire</u>	<u>Elements</u>	<u>Kh</u>	<u>Register Ratio</u>	
					<u>5-dial x 1</u>	<u>4-dial x 10</u>
2.5-200	120	3	2	14.4	6 17/18	69 4/9
	240	3	2	28.8	3 17/36	34 13/18
	480	3	2	57.6	1 53/72	17 13/16

DESCRIPTION

This meter is the same as the 100 amp meter approved under E-122 dated June 21, 1973 with the exception of the 200A current coils and different register ratios. There is no test dial since the lowest reading dial makes one complete revolution in less than one hour when the meter is running on 100 amperes.

Approval granted to:

Westinghouse Canada Limited,
Hamilton, Ontario.

J.L. Armstrong, P. Eng.,
Chief, Standards Laboratory,

Metrology and Laboratory Services

D.L. Smith, P. Eng.,
Chief, Electricity & Gas Division

Ref: 6565-C3-6

