



Ottawa, May 20, 1980

**NOTICE OF APPROVAL – AVIS D'APPROBATION**

WESTINGHOUSE CANADA TYPE "D4S-8" 100 AMP AND 200 AMP AND "D4A-8" 100 AMP SELF-CONTAINED POLYPHASE WATTHOUR METERS

This notice is an extension of Approval E-122-1 to include 100 and 200 amp ratings of the Type D4S-8 and D4A-8 already approved on that approval notice.

E-122 and all previous extensions remain in effect.

TYPE D4S-8 100A and 200A  
TYPE D4A-8 100 Amp


<u>CURRENT RANGE</u>	<u>VOLTAGE</u>	<u>WIRE</u>	<u>ELEMENTS</u>	<u>Kh</u>	<u>REGISTER RATIO</u>
1.2-100	120 <sup>(1)</sup>	4-Y	2 1/2	10.8	9 7/27 (5 dial x 1) 92 16/27 (4 dial x 10)
	240 <sup>(2)</sup>	4-Y	2 1/2	21.6	4 17/27 (5 dial x 1) 46 8/27 (4 dial x 10)
2.5-200	120 <sup>(1)</sup>	4-Y	2 1/2	21.6	4 17/27 (5 dial x 1) 46 8/27 (4 dial x 10)
	240 <sup>(2)</sup>	4-Y	2 1/2	43.2	2 17/54 (5 dial x 1) 23 4/27 (4 dial x 10)

(1) For use on 120/208 volt circuits

(2) For use on 277/480 volt circuits

Description: These meters are the same as the 10 amp meter of the same type designation approved under E-122-1 dated 16 August 1976, with the exception of the 100 and 200 amp coils and different register ratios.

Approval granted to: Westinghouse Canada Limited  
Hamilton, Ontario

.....  
  
 John Armstrong  
 Acting Chief  
 Electricity & Gas Division  
 Legal Metrology Branch

Ref: 6565-C3-6