



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-132-2

Ottawa, 26 February 1980

WESTINGHOUSE "TYPE WR-31" DEMAND RECORDER AND  
TYPE CDI-22 ARSH PULSE INITIATOR COMBINATION

This Notice of Approval covers a design modification to the apparatus approved under Notice of Approval E-132-1, dated May 2, 1979.

In the new design, only the sensing head remains inside the meter, the remaining circuitry having been relocated inside the recorder chassis.

In addition, the circuitry to change to battery operation on power failure has been revised from an electromechanical relay to a solid state circuit.

Approval granted to:

Westinghouse Canada Limited  
Hamilton, Ontario

John Armstrong  
Acting Chief  
Electricity and Gas Division  
Legal Metrology Branch

Ref: G 6565-C3-43