



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-145-1

Ottawa, July 7, 1978

WESTINGHOUSE TYPES WR32 AND WR34  
MAGNETIC TAPE RECORDERS

This notice covers the use of a "Flexitest" case modified for surface mounting and front wiring of types WR32 and WR34 recorders, retaining the draw out feature.

The modification consists of mounting a 10 pole terminal block for the type WR32 or a 13 pole terminal block for the type WR34 inside the case on the lower back surface and providing conduit entrances on each side and the back.

The entrances not being used will have plugs installed to block the opening. There will also be two mounting holes in the rear surface of the case to attach the recorder case to the mounting surface.

This notice is an amendment to E-145 which remains in force.

Approval Granted to:

Westinghouse Canada Limited  
Hamilton, Ontario

D. L. Smith  
Chief, Electricity and Gas Division  
Legal Metrology Branch

Ref: G 6565-C3-46