

**NOTICE OF APPROVAL
AVIS D'APPROBATION**

E-150-1

Ottawa, 22 May 1980

WESTINGHOUSE MECHANICAL DEMAND REGISTER MKIIIIa

This notice constitutes an addition to Notice of Approval E-150 which remains in effect.

In addition to the demand dial configuration depicted in E-150, approval is hereby granted to modify the MKIIIIa register to include the option of displaying demand units in watts rather than in kilowatts.

The modification consists of screwing a scale plate with the decimal bar omitted and having a fourth dummy dial at the extreme right, over the existing dial face. The three highest reading dials remain active, with the full scale capacity being indicated by a black mask on the highest reading dial as previously approved. The dummy pointer of the dial on the extreme right permanently indicates zero which is the only numeral shown.

Approval granted to:

Westinghouse Canada Limited
Hamilton, Ontario



Acting Chief
Electricity and Gas Division
Legal Metrology Branch

Ref: G 6565-C3-10