



Consumer and  
Corporate Affairs

Consommation et  
corporations

Standards

Normes

**NOTICE OF APPROVAL  
AVIS D'APPROBATION**

E-161-1

Ottawa, 26 February 1980

WESTINGHOUSE TYPE W-7 ISOLATION RELAY

This Notice constitutes an extension to Approval Notice E-161 dated April 5, 1979, to cover the incorporation of an Adams & Westlake sensitive relay type MWS16482-1B, or equivalent.

The operating current of this relay is  $\pm 13.5$  ma dc minimum with a coil resistance of 12 ohms  $\pm 10\%$  which would be shown on the nameplate of units so affected.

Except for the above noted change in coil characteristics, the remainder of the description of Approval Notice E-161 remains applicable.

Approval granted to:

Westinghouse Canada Limited  
Hamilton, Ontario

John Armstrong  
Acting Chief  
Electricity and Gas Division  
Legal Metrology Branch

Ref: G 6565-C3-43