

Consumer and Corporate Affairs Canada

Direction de la Métrologie légale

Legal Metrology Branch

Holland Avenue Ottawa, Ontario K1A 0C9

Avenue Holland Ottawa, Ontario K1 A 0C9 boratories

Legal Metrology Laboratories Telephone: (613) 990-8621 Your file Votre référence

Our file Notre référence O6565-P975 February 25, 1985 AML-E-7

Young Utility Equipment Inc.
Energy Management Products Division
55 Nugget Avenue
Agincourt, Ontario
M1S 3L1
Attention: Mr. W.B. Ball, P. Eng.

Dear Mr. Ball:

This is in response to your letter of February 15, 1985, regarding the modification to the enclosure of the Process Systems, Sentry 100C Solid State Pulse Recorder, previously approved under Notices of Approval E-197 and E-197-1. I am advised that the Electrical Laboratory has evaluated the re-location of the external plug for the hand held reader to an optional location inside the cover and concluded that it may be regarded as insignificant in relation to the approval provisions of the Electricity Inspection Act.

Accordingly, persuant to the authority delegated to me under the said Act:

- 1. your letter is hereby acknowledged as satisfying the notification requirements of subsection 6(4)(a) of the Electricity Meter Regulations C.R.C.1978, chapter 561, and
- the proposed alteration is hereby accepted, in accordance with the aforementioned subsection as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity Inspection Act are being informed of this decision by a copy of this letter.

Yours truly,

W.R. Virtue, Chief

Legal Metrology Laboratories

cc: Electrical Approvals Distribution List

