



Industry and Science
Canada

Industrie et Sciences
Canada

Legal Metrology
Branch

Direction de la
Metrologie legale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Telephone: (613)952-0635

File N°: 06565-S771
Project: AP-EL-86-0007
AP-EL-86-0023
AP-EL-85-0033
AP-EL-87-0049

Scientific Columbus Company
1900 Arlington Lane
Columbus, Ohio
USA 43228-4105
Attention: Mr. Bill Jones

1993-09-23

Dear Mr. Jones:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notices of Approval E-199, E-214, E-218, E-219 and E-232. It is noted that these devices are approved as follows:

- Demand may be 20 minutes fixed (block) interval, or 20 minutes sliding window with a 1, 2, 4, 5 or 10 minute sub-interval.

I am advised by the Electrical Metrology Laboratory that its evaluation of your notification indicates that it is accepted as being included within the above-noted approvals. All recipients of the approval notices are being informed by copy of this letter.

Yours truly,

H.L. Fraser, Chief
Electricity and Gas

cc: Approvals Mailing List