**.** 

Consumer and Corporate Affairs Canada Consommation et Corporations Canada

Legal Metrology Branch Direction de la Métrologie légale

Holland Avenue Ottawa, Ontario K1A 0C9 Avenue Holland Ottawa, Ontario K1A 0C9

Telephone: (613)952-0640

Your file Votre référence

Our file Notre référence

File N°: 06565

Project: AP-EL-89-0057

1989-11-09

Asea Brown Boveri Inc. 249 Dufferin St. S. P.O. Box 1600 Alliston, Ontario LOM 1A0 Attention: Mr. Eric Newbold

Dear Mr. Newbold,

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval E-82, E-82-1, E-82-2, E-119, E-122, E-122-1, E-122-2, E-122-3, E-122-4, E-122-5, E-122-6, E-122-7, E-133, E-133-1, E-138, E-149, E-160, E-160-1, E-194, E-194-1, E-194-2, E-195, E-211 Rev. 1, E-212, E-243, E-243 Add. 1, E-257, E-258, E-262, E-263, E-264, E-270. It is noted that these devices are to be modified as follows:

the pinion on the first pointer shaft of the registers for D4 and D5 Westinghouse single and polyphase watthour meters may be die-cast.

I am advised by the Electrical Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

W.R. Virtue, Chief

Legal Metrology Laboratories

cc: Approvals Mailing List

