



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file Votre référence

Our file Notre référence

Telephone: (613)952-0640

File N°: 06565
Project: AP-EL-90-0060

Iris Systems Inc.
355-435 Ellice Ave.
Winnipeg, Manitoba
R3B 1Y6
Attention: Mr. Dave Whalen

1990-09-19

Dear Mr. Whalen:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notices of Approval E-88, E-116, E-121, E-224, E-228, and E-240. It is noted that these devices are to be modified as follows:

- Installation of a Meter Guard Unit (MGU) inside meter for purpose of field trial of theft of service detection technology;
- MGU is an electronic device enclosed in plastic; no moving parts of the meter are touched by the MGU;
- Segment of meter disk is painted with flat black enamel;
- Original meter nameplate remains in original position;
- MGU shall not be used for billing purposes.

I am advised by the Electrical Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

W.R. Virtue, Chief
Legal Metrology Laboratories

cc: Approvals Mailing List

Canada