



Consumer and  
Corporate Affairs Canada

Legal Metrology

Consommation  
et Corporations Canada

Métrieologie légale

APPROVAL No. - N° D'APPROBATION

E-230 Rev. 2 Add 2

SFP 12 1988

**NOTICE OF APPROVAL**

**AVIS D'APPROBATION**

**ADDENDUM**

This is an addendum to a Notice of  
Approval issued to:

Le présent supplément est un ajout à  
l'avis d'approbation émis au nom de:

Canadian General Electric  
1130 boulevard Charest ouest,  
Quebec, Quebec  
G1N 2E2

ADD:

AJOUTER:

0.12-10A, 240V, 2 Wire, Transformer  
Type

0.12-10A, 240V, 2 fils, type à trans-  
formateur

W.R. Virtue

Chief  
Legal Metrology Laboratories

Chef  
Laboratoires de la Métrieologie légale

FILE/DOSSIER: 06565-AP-EL-88-0048  
PROJECT/PROJET: AP-EL-88-0048



SEAPORT91

## Begin New Directory

***SEAPORT IMAGING***

---

Ensign™

Scanner Type: ALL

---

Function: Begin New Directory

---

Creates new directory at same level as current directory

---

by incrementing directory name.

---

---





Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology  
Branch

Direction de la  
Métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

Your file    *Votre référence*

Our file    *Notre référence*

Telephone: (613)952-0640

File N°: 06565  
Project: AP-EL-89-0027

Sangamo Electricity Division  
Schlumberger Industries  
215 Laird Drive  
Toronto, Ontario M4G 3X1  
Attn: Mr. Marc Purc

1989-06-20

Dear Mr. Purc,

This is in response to your recent notification given in accordance with the Electricity & Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval E-254. It is noted that these devices are to be modified as follows:

- Optional configuration to display individual phase measurement quantities which are not used for billing. Meter measurement circuitry and firmware remains unchanged. When configured thus, type designation ST-Q121 becomes ST-Q200 for conventional system and to ST-2300 for system measurement which includes neutral current.

I am advised by the Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

W.R. Virtue, Chief  
Legal Metrology Laboratories

cc: Approvals Mailing List

Canada

