



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file *Votre référence*

Our file *Notre référence*

Telephone: (613) 952-0635

File N°: 06565

Project: AP-EL-92-0029

1992-08-25

Schlumberger Industries
Sangamo Electricity Division
215 Laird Drive
Toronto, Ontario M4G 3X1
Attention: Mr. Marc Purc

Dear Mr. Purc:

This is in response to your recent notification given in accordance with the Electricity and Gas Inspections Regulations, Section 13, regarding devices approved under Notice of Approval E-231 Rev. 1. It is noted that these devices are to be modified as follows:

- . The material of the fastener joining the demand pointer to the thermal element has been changed from aluminum alloy to polyphenylene sulphide (PPS) which has better high temperature stability characteristics.

I am advised by the Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

H.L. Fraser, Chief
Electricity and Gas

cc: Approvals Mailing List

Canada