



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology  
Branch

Direction de la  
Métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0G9  
Legal Metrology Laboratories  
Telephone: (613) 952-0615

Avenue Holland  
Ottawa, Ontario  
K1A 0G9

Your file    Votre référence

Our file    Notre référence

06565-Q31  
AP-EL-87-0054  
August 22, 1988  
AML-E-41

Hydro Quebec  
201 Jarry Street, West  
Montreal, Quebec  
H2P 1S7  
Attention: Mr. R. Foisy

Dear Mr. Foisy:


This is in response to your letter dated August 19, 1988, regarding Notices of Approval E-236 and E-237, and proposing to modify Single Phase Watthour Meter Thermal Controls approved therein by adding an optional N.O. (normally open) contact on the relay and wired to the terminal block.

I am advised that, upon evaluation of the proposed modifications, the Electrical Laboratory has concluded that they may be regarded as immaterial in relation to the approval provisions of the Electricity and Gas Inspection Act. Accordingly, pursuant to the authority delegated to me under the said Act:

1. your letter is hereby acknowledged as satisfying the notification requirements of section 13, Part III of the Electricity and Gas Inspection Regulations, SOR/86-131, 16 January, 1986, and
2. the proposed alteration is hereby accepted, in accordance with the aforementioned section, as being an immaterial one and hence included within the approval.

All recipients of Notices of Approval under the Electricity and Gas Inspection Act are being informed of this decision by copy of this letter.

Yours truly,

  
W.R. Virtue  
Chief

cc: Mailing List (Electrical Approvals)

**Canada**