



Consumer and  
Corporate Affairs Canada

Consommation  
et Corporations Canada

Legal Metrology  
Branch

Direction de la  
Métrologie légale

Holland Avenue  
Ottawa, Ontario  
K1A 0C9

Avenue Holland  
Ottawa, Ontario  
K1A 0C9

*Your file* *Voire référence*

*Our file* *Notre référence*

Telephone: (613)952-0615

File N°: 06565  
Project: AP-EL-88-0028

Sangamo Company Limited  
215 Laird Drive  
Toronto, Ontario  
M4G 3X6  
Attn: Mr. M. Purc

1988-11-25


Dear Mr. Purc,

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval E-248. It is noted that these devices are to be modified as follows:

- Replacement of the controller board assembly in the Sangamo model TC single phase thermal watt-hour meter by an equivalent assembly manufactured by Micro Controle and used in their model MC4441 meter approved under notice E-251.

I am advised by the Electrical Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

  
W.R. Virtue, Chief  
Legal Metrology Laboratories

cc: Approvals Mailing List

Canada