



Consumer and
Corporate Affairs Canada

Consommation
et Corporations Canada

Legal Metrology
Branch

Direction de la
Métrologie légale

Holland Avenue
Ottawa, Ontario
K1A 0C9

Avenue Holland
Ottawa, Ontario
K1A 0C9

Your file *Voire référence*

Our file *Notre référence*

Telephone: (613)952-0640

File N°: 06565-S2
Project: AP-EL-89-0014

Sangamo Electricity Division
Schlumberger (Canada) Ltd.
215 Laird Drive
Toronto, Ontario
M4G 3X1
Attn: Mr. M. Purc

1989-04-25

Dear Mr. Purc:,

This is in response to your recent notification given in accordance with the Electricity and Gas Inspection Regulations, Section 13, regarding devices approved under Notice of Approval E-254. It is noted that these devices are to be modified as follows:

- Alternate display Optrex DMC16230H with 9.66 mm characters in place of Optrex DMC16207H with 5.55 mm characters.
- Modified face plate to accommodate larger display.
- With larger display, model designation ST-Q100 becomes ST-Q101, ST-Q110 becomes ST-Q-111 and ST-Q120 becomes ST-Q121.

I am advised by the Electrical Metrology Laboratory that their evaluation of the proposed modifications indicates that they may be regarded as immaterial in relation to the approval provisions of the Act. Accordingly, your notification is acknowledged and the modifications are accepted as being included within the above-noted approval. All recipients of the approval notice are being informed by copy of this letter.

Yours truly,

W.R. Virtue, Chief
Legal Metrology Laboratories

cc: Approvals Mailing List

Canada