

DEPARTMENT OF TRADE AND COMMERCE
Electrical and Gas Standards Laboratories


Ottawa, January 17th, 1931.

District Inspectors of Electricity & Gas:-

Re: General Electric Type M.13 Demand Meter

Dear Sirs, - I beg to advise you that the type M.13, 25 cycle, demand meter, manufactured by the Canadian General Electric Company, Toronto, Canada, has been approved by the National Research Council for use in Canada on circuits where the regulation of frequency is such that a normal operation between $24\frac{1}{2}$ and $25\frac{1}{2}$ cycles is assured.

Yours truly,



Director.