

DEPARTMENT OF TRADE AND COMMERCE
Electrical and Gas Standards Laboratories


Ottawa, May 1st, 1931.

District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the type 4L.2 Lincoln-Sangamo polyphase demand energy meter, manufactured by the Sangamo Company, Limited, Toronto, Canada, has been approved by the National Research Council and may be admitted to verification in Canada.

This meter is of the same design as the 4L meter but the heating element is of bakelite construction and the watt-hour meter elements are of the S.3 type, both of which were approved recently by the National Research Council.

Yours truly,



Director.