

DEPARTMENT OF TRADE AND COMMERCE
Electricity and Gas Inspection Services

Ottawa, August 14th, 1933.

District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the type OC single phase, 2 and 3 wire, watt-hour meter of the following ratings, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ontario, has been approved by the National Research Council and may be admitted to verification in Canada.


The ratings are:

Amperes - $2\frac{1}{2}$, 5, 10, 15 and 25.

Volts - 115, 230, 460 and 575.

Cycles - 60.

Yours faithfully,


Director.

DEPARTMENT OF TRADE AND COMMERCE

Electricity and Gas Inspection Services

Ottawa, August 28th, 1933.

District Inspectors of Electricity & Gas:-

Dear Sirs,- I beg to advise you that the type CC, single phase, 2 and 3 wire, watt-hour meter, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ont., has been approved by the National Research Council and may be admitted to verification in Canada.

The ratings of the meters which have been approved are as follows:

Amperes - $2\frac{1}{2}$, 5, 10, 15, 25 and 50.

Volts - 115, 230, 460 and 575.

Cycles - 25.

Yours truly,


Director.

JLS/RS.