

DEPARTMENT OF TRADE AND COMMERCE  
ELECTRICITY AND GAS INSPECTION SERVICES

OTTAWA, October 17, 1933.

District Inspectors of Electricity & Gas-

Dear Sirs,- I beg to advise you that the type CS, single phase, 2 and 3 wire, watt-hour meter, manufactured by the Canadian Westinghouse Company, Limited, Hamilton, Ont., has been approved by the National Research Council and may be admitted to verification in Canada.


The ratings of the meters which have been approved are as follows:-

Amperes - 2½, 5, 10, 15, 25 and 50.

Volts - 115, 230, 460 and 575.

Cycles - 25 and 60.

Yours truly,

  
Director.

JLS/RS.